

## ROUGH IN & UNDERGROUND PLUMBING CHECKLIST

YES NO

- ☐ ☐ Proper connection for ejection system
- ☐ ☐ 5 lb. air test on drains & vents
- ☐ ☐ Proper slope on drainage
- ☐ ☐ Sleeve or arch through / under footers or walls
- ☐ ☐ Proper pipe support / strapping
- ☐ ☐ Cleanouts where required
- ☐ ☐ Air test on waterlines
- ☐ ☐ Fixture count
- ☐ ☐ Building drain size
- ☐ ☐ # of building drains exiting the building
- ☐ ☐ Main vent terminates properly through roof
- ☐ ☐ Water heater installed
- ☐ ☐ Shutoff valve on inlet
- ☐ ☐ Expansion tank required
- ☐ ☐ Vacuum relief valve required----- for bottom fed water heaters----
- ☐ ☐ Ignition source 18" above garage floor
- ☐ ☐ Pan required
- ☐ ☐ Pan and T&P terminate to proper receptacle
- ☐ ☐ Hammer arrestors installed for quick closing valves
- ☐ ☐ Backflow on water supply piping
- ☐ ☐ Waterlines properly supported
- ☐ ☐ Circulating loops insulated – if applicable--
- ☐ ☐ Pressure balanced faucets installed where required
- ☐ ☐ Anti siphon on hose bibs & lawn faucets
- ☐ ☐ Shutoff valves for lawn faucets
- ☐ ☐ Primer for floor drains
- ☐ ☐ Sump pump discharge drains properly supported
- ☐ ☐ Boca / stud plates where required

COMMENTS